




Energy consumption impact review

Client	Temple Golf Club	Existing	£7,441.10
Address	Hurley, Maidenhead, Berkshire SL6 5LH	Identified saving	£2,514.07
		Per centage	33.79%

	Existing			Alternative			
	KWH/Annum	Cost	tCO2e	KWH/Annum	Saving KWH/Ann.	Annual savings £	tCO2e savings
Heating	13,978	£1,257.98	7.60	10,483	3,494	£314.50	1.90
Cooling	42,774	£3,849.63	23.27	42,774	7,699	£692.93	4.19
Lighting	25,928	£2,333.48	14.10	25,928	16,740	£1,506.64	9.11
Total	82,679	£7,441.10	44.98	79,184	27,934	£2,514.07	15.20

Summary of existing

Source	Kwhr/Annum
Heating	13,978
Cooling	42,774
Lighting	25,928



Possible savings

Source	Existing Kwhr	Possible Kwhr
Heating	13,978	10,483
Cooling	42,774	35,074
Lighting	25,928	9,187

